



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-122, **Version:** 2

Appeal of Keven Steen, Wellington Window & Door Company, on behalf of Kendra Liu, to an Egress Window Non-Compliance Determination at 2099 PINEHURST AVENUE.

One window does not meet the minimum height requirement.

March 3, 2011

David Tank

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Keven Steen, Wellington Window & Door Company, on behalf of Kendra Liu, to an Egress Window Non-Compliance Determination at 2099 PINEHURST AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 24 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.