



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-45, **Version:** 2

Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1686 IDAHO AVENUE EAST.

#1 - Bedroom. Request variance on openable height.

January 12, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1686 IDAHO AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.