



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 10-104, **Version:** 1

---

Appeal of Jason Nordhogen to a Certificate of Occupancy Deficiency List for property at 1023 Bradley Street (Ward 5)

1023 Bradley Street

Window meets total minimum size but is approximately 4" short of opening height. It is 7" wider than the required minimum.

August 16, 2010

September 7, 2010

Grant without hearing.

Grant a 4-inch variance on the openable height of the egress window in the west bedroom.

[Enter the target date for this item to be introduced to Council]