



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-108, **Version:** 2

Appeal of Nate Armstrong, on behalf of Calhoun Ventures, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1348 THIRD STREET EAST.

Basement bedroom ceiling height is 6'9" (81") vs. 7'

May 10, 2011

WHEREAS, in the matter of the Appeal of Nate Armstrong, on behalf of Calhoun Ventures, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1348 THIRD STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a variance on the ceiling height issue in the basement bedroom; Now, Therefore, Be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.