



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-559, **Version:** 1

Appeal of Yemane Mebrahtu to a Fire Inspection Correction Notice at 849 OTTO AVENUE.

It is a townhouse with 11 units. They were built in 1982. They all have the same safety footage and size. 849 is one of them. The windows conditions are good, except they are not as big as required because at the time they were built the requirement was not in affect.

December 15, 2010

No hearing necessary. Recommend variance on egress window dimensions.