



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 11-368, **Version:** 1

---

Appeal of Patrick Clemens to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 225 WILDER STREET NORTH.

Current ownership just purchased this property on January 7 of this year and has corrected all other deficiencies on the list. Windows in the bedroom in question are newer replacement, double-hung windows that fall just outside the allowable dimensions for egress. While the window opening is not tall enough, its width and overall size exceed minimum standards for egress. In lieu of replacing a newer quality window, we are asking to have this correction waived.

January 31, 2011

No hearing Necessary. Recommend variance on egress window dimensions.