



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-185, **Version:** 2

Appeal of James Bobzien to an Updated Fire Inspection Correction Notice at 1637 VAN BUREN AVENUE.

See attachment - Page 1

May 4, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of James Bobzien to an Updated Fire Inspection Correction Notice at 1637 VAN BUREN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable height of the egress window in the third floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.