



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 11-74, **Version:** 2

---

Appeal of David and Jeannette Morisette to a Fire Certificate of Occupancy Correction Notice at 1539 BIRMINGHAM STREET.

I am appealing Item 3 on the attached April 18, 2011 Fire Inspection Correction Notice. The dryer exhaust ducts are 4" and are constructed of smooth metal. There are no transition ducts as referenced in the Minnesota Mechanical Code (attached) and therefore labeling is not required. Per code 504.2, the exhaust penetration goes through an outside building wall which is not required to be fire resistant therefore construction of galvanized steel is not required.

April 18, 2011

Grant the appeal for the dryer exhaust ducts.

WHEREAS, in the matter of the appeal of David and Jeannette Morisette to a Fire Certificate of Occupancy Correction Notice at 1539 BIRMINGHAM STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal for the dryer exhaust ducts; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.