



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-63, **Version:** 2

Appeal of Molly McGrane, Window World, to an Egress Window Non-Compliance Determination at 905 WHITE BEAR AVENUE NORTH.

Windows

May 8, 2011

David Nelson

No hearing necessary. Note condition listed below has been met, per DSI staff.

Yes, 6 inches minimum sill height, on condition that at least 1 standard dimension step for length of window.

WHEREAS, in the matter of the Appeal of Molly McGrane, Window World, to an Egress Window Non-Compliance Determination at 905 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the sill height provided the owner installs steps below the egress windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.