



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 13-5, **Version:** 2

Appeal of Roseanne Wynn to an Egress Window Non-Compliance Determination at 1415 MARGARET STREET.

See Correction Notice. I am asking for a variance.

February 7, 2013

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height for main level northeast and southeast bedrooms.

WHEREAS, in the matter of the Appeal of Roseanne Wynn to an Egress Window Non-Compliance Determination at 1415 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the main level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.