



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 17-103, **Version:** 2

Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 279 WESTERN AVENUE NORTH, Townhouses A through L.

WHEREAS, in the matter of the Appeal of Catherine Breier, President of Property Solutions and Services, managing agent for Liberty Plaza, to a Fire Inspection Correction Notice at 279 Western Avenue North, Townhouses A through L, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the carbon monoxide alarm detectors, as there is no carbon monoxide-emitting equipment on site, and deny the appeal on the blocked egress; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.