



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-177, **Version:** 2

Appeal of Lesley White-Kayser to a Fire Inspection Correction Notice at 902 YOUNG STREET.

Egress window

April 30, 2012

Sebastian Migdal

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Lesley White-Kayser to a Fire Inspection Correction Notice at 902 YOUNG STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable height of the egress window in the main level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.