



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 13-170, **Version:** 2

---

Appeal of Tammi Timm to a Correction Notice-Daycare Inspection at 1341 ROSS AVENUE.

Windows in sleeping rooms are 33 inches wide and open 17 inches high (instead of the 20 side and 24 high). These windows are in the original window openings. I've lived here 19 years and replaced windows about 15 years ago so the windows are not original. These are main floor windows.

July 2, 2013

James Perucca

No hearing necessary.

Yes, a 7 inch variance for the egress opening height of the listed windows.

WHEREAS, in the matter of the Appeal of Tammi Timm to a Correction Notice-Daycare Inspection at 1341 ROSS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the northeast and southeast bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.