



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-204, **Version:** 2

---

Appeal of George Deuth to a Fire Certificate of Occupancy Correction Notice at 584 FARRINGTON STREET.

Windows

October 11, 2011

Yes, 2 inches egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of George Deuth to a Fire Certificate of Occupancy Correction Notice at 584 FARRINGTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of the egress window in the second floor northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.