



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-22, **Version:** 2

Appeal of Roxberg Rehab to an Egress Window Non-Compliance Determination at 81 GEORGE STREET WEST.

(Nothing noted)

May 20, 2011

WHEREAS, in the matter of Appeal of Roxberg Rehab to an Egress Window Non-Compliance Determination at 81 GEORGE STREET WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends granting a variance for the one double hung window measuring 16 inches wide by 34 inches high on the condition that the room is not being used as a sleeping room; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.