



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-242, **Version:** 2

---

Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1098 WAKEFIELD AVENUE.

#2 - Egress windows MSFC 1026.1. Request variance on openable height.

October 19, 2011

Wayne Spiering

No hearing.

Yes, 5 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 1098 WAKEFIELD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 4.5-inch variance on the openable height of the egress windows in the main floor northwest, southwest, and southeast bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.