



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-88, **Version:** 2

Appeal of the Department of Public Health, on behalf of Kelly Dehn, to an Egress Window Non-Compliance Determination at 300 CLARENCE AVENUE.

Egress window dimensions.

Yes, 3 inches in egress opening height.

WHEREAS, in the matter of the Appeal of the Department of Public Health, Daniel Schmidt, to an Egress Window Non-Compliance Determination at 300 CLARENCE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable height of one wood acraft tilt-pac replacement egress bedroom window measuring 21.5 inches high by 22.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.