



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-76, **Version:** 2

Appeal of Blia Lee to an Egress Window Non-Compliance Determination at 1672 CONWAY STREET.

All the windows are still original that were built with the house and will not be changed.

September 22, 2011

Yes, 8 inches in egress opening height. No hearing necessary.

Permit Staff: Please initial or sign forms to confirm DSI staff has reviewed/issued the permit denial.

WHEREAS, in the matter of the Appeal of Blia Lee to an Egress Window Non-Compliance Determination at 1672 CONWAY STREET; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of five double-hung replacement egress bedroom windows measuring 16 inches high by 34 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.