



Legislation Text

File #: RLH FOW 11-60, **Version:** 2

Appeal of Tong Khang to a Correction Notice-Complaint Inspection at 192 WHEELLOCK PARKWAY WEST.

3 windows together grouped up

17" by 48"

When we bought the house, the windows were like this already.

May 12, 2011

Yes. 3 inches in the openable width for egress windows in daycare.

WHEREAS, in the matter of the Appeal of Tong Khang to a Correction Notice-Complaint Inspection at 192 WHEELLOCK PARKWAY WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; And

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.