



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-184, **Version:** 2

Appeal of Robert Leonetti to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1089 GERANIUM AVENUE EAST.

Window only

April 24, 2012

Mike Cassidy

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Robert Leonetti to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1089 GERANIUM AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in middle bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.