



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-221, **Version:** 2

Appeal of Roxanne W. Larsen to a Fire Inspection Correction Notice at 684 ROSE AVENUE EAST.

See attachment

May 2, 2012

Benjamin Ellis

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Roxanne W. Larsen to a Fire Inspection Correction Notice at 684 ROSE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the first floor south and north bedroom and second floor south and north bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.