



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-292, **Version:** 1

Appeal of Renewal by Andersen on behalf of Mary Jo Katras to an Egress window non-compliance determination at 2005 Stanford Avenue

2005 Stanford Avenue

Egress Window

10-20-10

No hearing necessary, as only windows under appeal.

Grant variance of 1 1/8" in openable height for 5 double hung windows with egress opening of 24" width and 22 7/8" height

Grant variance of 1 1/8" in openable height for 4 double hung windows with egress opening of 20" width and 22 7/8" height