



Legislation Text

File #: ALH 10-326, **Version:** 1

Appeal of Xai Thao to a Fire Certificate of Occupancy Correction Order at **219 WHITE BEAR AVENUE NORTH.**

Egress windows.

September 29, 2010

No hearing necessary.

For upper floor northwest and northeast bedrooms (double hung): recommend variance on egress window opening height of 4" in height.

For basement southeast and northwest bedrooms (double hung): recommend variance on egress window opening height of 8" in height. Also, recommend variance on maximum sill height of 2" if a step of standard size is installed permanently affixed to the wall and running the entire width of the window.

For basement west bedroom (double hung): recommend variance on egress window opening height of 8" in height. Also, recommend variance on maximum sill height of 2" if a step of standard size is installed permanently affixed to the wall and running the entire width of the window.