



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 11-288, **Version:** 2

---

Appeal of Conrad Preiner to a Fire Certificate of Occupancy Correction Notice at 1210 MAGNOLIA AVENUE EAST.

See pictures and documentation

July 26, 2011

Yes, 4 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Conrad Preiner to a Fire Certificate of Occupancy Correction Notice at 1210 MAGNOLIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the windows in each bedroom measuring 20.5 inches openable height X 23.5 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.