



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 16-97, **Version:** 2

Appeal of Bill Hosko to a Fire Certificate of Occupancy with Deficiencies at 151 SEVENTH STREET EAST.

AMENDED 8/17/16

WHEREAS, in the matter of the Appeal of Bill Hosko to a Fire Certificate of Occupancy with Deficiencies at 151 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council ~~allow owner to keep the trees if they are treated with approved flame retardant material and legislative hearing officer will work with City's fire engineer on what products are approved for this use~~ 1) allow, per the recommendation of the Fire Engineer, the use of Flame Guard fire retardant on the trees (not living) as an alternative means of compliance with the orders on the over abundance of trees and 2) grant 2 months to come into compliance with the orders; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.