



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-513, **Version:** 1

Appeal of Sergio Rodriguez to a Fire Inspection Correction Notice at 351 LAWSON AVENUE EAST.

Interior both units - MSFC 1026.1. Windows must be min. 5 square ft. glazed area with min. 24 " openable ht + 20" openable width.

Our double hung windows measured 19" openable ht. * 26" openable width.

Appeal because new windows and the width is bigger than the ht. required, and the bedrooms are close to the 2nd bedrooms that have required measurements on windows.

November 23, 2010

No hearing Necessary. Recommend grant of a variance.