



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-61, **Version:** 2

Appeal of Molly McGrane, on behalf of Window World, to an Egress Window Non-Compliance Determination at 1631 BIRMINGHAM STREET.

Windows

May 8, 2012

David Nelson

WHEREAS, in the matter of the Appeal of Molly McGrane, on behalf of Window World, to an Egress Window Non-Compliance Determination at 1631 BIRMINGHAM STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny a variance on the awning egress window replacement measuring 12 inches high by 40 inches wide; and deny a variance on the sill height issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.