



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-69, **Version:** 2

---

Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 963 JUNO AVENUE.

Windows

June 6, 2012

None listed.

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 963 JUNO AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 23.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.