



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 13-259, **Version:** 2

Appeal of Linda McInerney to a Daycare Inspection Correction Notice at 66 FLANDRAU PLACE.

Second Floor bedroom windows-Page 2 #8 of attachment. Fire inspection for opening of child day care. The 2nd floor will not be used for child day care purposes.

November 22, 2013

James Perucca

No hearing necessary.

Yes, 8 inches egress opening height for all second floor bedroom windows.

WHEREAS, in the matter of the Appeal of Linda McInerney to a Correction Notice-Reinspection Complaint at 66 FLANDRAU PLACE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress windows in the second floor bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.