



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-42, **Version:** 2

Appeal of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1298 SEMINARY AVENUE.

Windows

April 24, 2012

No hearing necessary.

Yes, 4.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1298 SEMINARY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4.5-inch variance on the openable height of three double hung replaceable egress bedroom windows measuring 19.9 inches high by 25.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.