



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-108, **Version:** 2

---

Appeal of A Pane In The Glass Construction, on behalf of Dan Notch, to an Egress Window Non-Compliance Determination at 1115 NORTON STREET.

Window sizes different than requirements.

October 31, 2011

DD

No hearing necessary.

3.5 inches egress opening width.

WHEREAS, in the matter of the Appeal of A Pane In The Glass Construction, on behalf of Dan Notch, to an Egress Window Non-Compliance Determination at 1115 NORTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable width of two slider replacement egress bedroom windows and one casement replacement egress window in the bathroom measuring 33.06 inches high by 16.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.