



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-104, **Version:** 2

Appeal of Mary Fasching to an Egress Window Non-Compliance Determination at 1486 IGLEHART AVENUE.

Orders to install new windows in two bedrooms.

March 3, 2011

Grant a 6.5-inch variance in south wall replacement window in 2nd floor east bedroom; grant a 7.5 variance in 2nd floor west bedroom; hearing on east wall bedroom on 2nd floor.

WHEREAS, in the matter of the appeal of Mary Fasching to an Egress Window Non-Compliance Determination at 1486 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7.5-inch variance on the openable height of the egress window in the 2nd floor west bedroom and grant a 6.5-inch variance on the openable height of the south wall replacement window in the 2nd floor east bedroom. ; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.