



Legislation Text

File #: RLH FOW 12-141, **Version:** 2

Appeal of Andy Hybben to a Fire Inspection Correction Notice at 625 SHERWOOD AVENUE.

Northwest and southwest bedroom windows

March 28, 2012

Mike Cassidy

No hearing necessary.

Yes, 7.5 inches egress opening height for the northwest bedroom. Yes, 4 inches egress opening height for the southwest bedroom. ORDERS WERE NOT NECESSARY FOR THE SOUTHWEST BEDROOM, GIVEN ITS DIMENSIONS.

WHEREAS, in the matter of the Appeal of Andy Hybben to a Fire Inspection Correction Notice at 625 SHERWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7.5-inch variance on the openable height of the egress window in the northwest bedroom and grant a 4-inch variance on the openable height of the egress window in the southwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.