



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-213, **Version:** 2

---

Appeal of Zaw Wai to a Fire Certificate of Occupancy Correction Notice at 933 FIFTH STREET EAST.

October 3, 2011

Yes - 5 inch variance in egress opening height of south bedroom window and 2 inch variance in egress opening height of north bedroom window. No hearing necessary.

WHEREAS, in the matter of the Appeal of Zaw Wai to a Fire Certificate of Occupancy Correction Notice at 933 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable height of four double hung replacement egress bedroom windows measuring 22.5 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.