



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-116, **Version:** 2

Appeal of Merric Bilotta to an Egress Window Non-Compliance Determination at 423 WYOMING STREET EAST.

Window variance: the windows meet the approved escape window size; however, the height and width are reversed. Mine is 24W X 22.5H. Requirement is 24h x 20.0 w.

July 19, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Merric Bilotta to an Egress Window Non-Compliance Determination at 423 WYOMING STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress windows in all sleeping rooms for Item 1; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.