



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-24, **Version:** 1

Appeal of Angen Xiong to an Egress Window Non-Compliance Determination at 1086 GALTIER STREET.

Window x 1

February 9, 2012

J. Hoffman

No hearing necessary.

Appeal was not entered into system until 2/23/12. Appeal got missed. -mxv

Grant 6-inch egress opening.

WHEREAS, in the matter of the Appeal of Angen Xiong to an Egress Window Non-Compliance Determination at 1086 GALTIER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a 6-inch variance on the openable height of one double hung replacement bedroom egress window measuring 18 inches high by 21 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.