



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 11-178, **Version:** 1

---

Appeal of Peter Vu to a Fire Inspection Correction Notice at 605 GREENBRIER STREET.

Windows do not open to 24" minimum. Windows are double hung style. Sits on Historic Dayton's Bluff neighborhood. Dayton's Bluff Preservation does not want change in windows style. Must keep double hung style.

January 21, 2011