



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-205, **Version:** 2

---

Appeal of Janet K. Erickson to a Fire Certificate of Occupancy Correction Notice at 1005-1007 ST. CLAIR AVENUE.

Item #5

October 3, 2011

Yes, 5 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Janet K. Erickson to a Fire Certificate of Occupancy Correction Notice at 1005-1007 ST. CLAIR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the north and south bedrooms of the upper and lower units; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.