



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-64, **Version:** 1

Appeal of Erick Simola to an Egress Window Non-Compliance Determination at 806 PARKWAY DRIVE.

Egress window was installed with a 5.11 height of 44". Upon inspection, it was found that the window opening has to be 44" from the ground. Mine is 44 from the frame and 47" to the opening.

No hearing necessary.

Return appeal and fee.

No variance necessary for sill height of 48". See attached policy.

WHEREAS, in the matter of the Appeal of Erick Simola to an Egress Window Non-Compliance Determination at 806 PARKWAY DRIVE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council [recommendation]; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.