



Legislation Text

File #: RLH FOW 11-87, **Version:** 2

Appeal of Steve Fuller to a Fire Certificate of Occupancy Inspection Correction Notice at 1694 MARGARET STREET.

Only Egress Windows

June 22, 2011

Yes, 2 inches in egress opening height.
No hearing necessary.

WHEREAS, in the matter of the Appeal of Steve Fuller to a Fire Certificate of Occupancy Inspection Correction Notice at 1694 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress bedroom window(s); Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.