



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-99, **Version:** 2

Appeal of Chai Lee to a Fire Certificate of Occupancy Inspection Correction Notice at 1184 JESSIE STREET.

Only egress windows

March 2, 2012

Mike Cassidy

No hearing necessary. Also, the egress opening is within a range where no order was necessary.

Yes, 1st floor north bedroom - 3 inches egress opening height and 2nd floor bedrooms - 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Chai Lee to a Fire Certificate of Occupancy Inspection Correction Notice at 1184 JESSIE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the first floor north bedroom and grant a 2-inch variance on the openable height of the egress windows in the 2nd floor north and west bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.