



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-244, **Version:** 2

---

Appeal of Four Corners Properties of Minnesota LLC to a Fire Inspection Correction Notice at 814 ENGLEWOOD AVENUE.

Windows - see attachment

June 5, 2012

Lisa Martin

WHEREAS, in the matter of the Appeal of Four Corners Properties of Minnesota LLC to a Fire Inspection Correction Notice at 814 ENGLEWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1 inch variance on the openable width and a 2 inch variance on the openable height of the egress windows in the upstairs bedrooms - noting that no variance is necessary if windows are not stuck; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.