



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-27, **Version:** 2

Appeal of James Stretch to an Egress Window Non-Compliance Determination at 833 PORTLAND AVENUE.

Egress Window (double-hung) is 5" less than required height (width is 21" under than required)

May 31, 2011

Yes, 5 inches in openable height. No hearing necessary.

WHEREAS, in the matter of the appeal of James Stretch to an Egress Window Non-Compliance Determination at 833 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19 inches high by 41 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.