



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-268, **Version:** 2

Appeal of Billy Vang to a Fire Certificate of Occupancy Correction Notice at 2044 HYACINTH AVENUE EAST.

Bedroom Windows SW & NW

December 7, 2011

James Thomas

Hearing necessary as SW Bedroom - 15 inches egress opening height.

Yes, NW Bedroom - 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Billy Vang to a Fire Certificate of Occupancy Correction Notice at 2044 HYACINTH AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the northwest side bedroom, and deny a variance on the southwest side bedroom egress window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.