



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 10-185, **Version:** 1

---

Appeal of Gerald Peterson to a Building Permit Non-Compliance Determination for Egress Window Dimensions at 1795 Hillcrest Avenue. (Ward 3)

4 1/2 " difference window height height from Code, 2 double hung windows.

September 8, 2010

October 12, 2010

No building permit non compliance determination attached, but dimensions are in STAMP system. 19 1/2"H x 27 1/2 "W. 28" from Floor and glazed area of 9.2 sq ft.

No hearing necessary. Grant appeal.

[Enter Recommendation, with specific references to items in orders, deadlines and extensions]