



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-70, **Version:** 2

Appeal of Brad Forester to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 54 PASCAL STREET SOUTH.

- Openable area of windows.
- Windows were installed by contractor in 2003. Contractor never scheduled final inspection.

February 7, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 4 inches in egress opening height and 2 inches egress opening width.

WHEREAS, in the matter of the Appeal of Brad Forester to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 54 PASCAL STREET SOUTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height and a 2-inch variance on the openable width of the egress window in the upper unit bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.