



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-99, **Version:** 2

Appeal of Robert Bray to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2068 SUBURBAN AVENUE.

My windows in the bedroom are the windows that came with the house.

15.5h X 37w openable

32h X 34w glazed

Inspector asked me to complete this form for a variance.

February 4, 2011

WHEREAS, in the matter of the appeal of Robert Bray to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2068 SUBURBAN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress windows in the main floor northeast, southeast, and southwest bedrooms; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.