



Legislation Text

File #: RLH FOW 11-39, **Version:** 2

Appeal of Charles R. Petrich to a Fire Certificate of Occupancy Approval With Corrections at 861 ALBERT STREET NORTH.

Window is existing in structure and passed inspection previously. The window matches the minimum sq. inches total.

April 27, 2011

Yes, 4" in egress opening width.

WHEREAS, in the matter of the appeal of Charles R. Petrich to a Fire Certificate of Occupancy Approval With Corrections at 861 ALBERT STREET NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4 inch variance in the egress window opening width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.