



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-165, **Version:** 2

---

Appeal of Rosa E. Arias to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1026 PROSPERITY AVENUE.

Only egress windows

September 13, 2011

Yes, for bedrooms on the southwest and southeast sides. Hearing on the basement windows.

WHEREAS, in the matter of the appeal of Rosa E. Arias to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1026 PROSPERITY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the southwest and southeast side bedrooms, and deny the appeal on the basement egress bedroom window and still height issues; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.