



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-132, **Version:** 2

Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET.

Window is compliant width and 2" short on height

April 2, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height. Note, orders not necessary on windows of these dimensions.

WHEREAS, in the matter of the Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.